

**AMON CARTER LAKE WATER SUPPLY CORPORATION**  
***METER TEST AUTHORIZATION AND TEST REPORT***

NAME: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

DATE OF REQUEST: \_\_\_\_\_ PHONE NUMBER (DAY): \_\_\_\_\_

ACCOUNT NUMBER: \_\_\_\_\_ METER SERIAL NUMBER: \_\_\_\_\_

REASONS FOR REQUEST: \_\_\_\_\_

Members requesting a meter test may be present during the test, but if not, Member shall accept test results shown by the Corporation. The test shall be conducted in accordance with the American Water Works Association standards and methods on a certified test bench or on-site with an acceptable certified test meter. Member agrees to pay \$300.00 for the test if the results indicate an AWWA acceptable performance, plus any outstanding water utility service. In the event that the Member is required to pay for the test and for outstanding water utility service as set forth herein, said charges shall be applied to the next billing sent to the Member after the date of the test.

\_\_\_\_\_  
Signed by Member

**TEST RESULTS**

Low Flow (1/4 GPM)	_____ %	AWWA Standard 97.0 - 103.0 %
Intermediate (2 GPM)	_____ %	AWWA Standard 98.5 - 101.5 %
High Flow (10 GPM)	_____ %	AWWA standard 98.5 - 101.5 %

Register test \_\_\_\_\_ minutes at \_\_\_\_\_ gallons per minute recorded per \_\_\_\_\_ gallons.

Meter tests accurately; no adjustments due.

Meter tests high; adjustment due on water charges by \_\_\_\_\_ %

Meter tests low; no adjustment due.

Test conducted by \_\_\_\_\_ Approved.